

# VOC Content Test Certificate

Monday, November 18<sup>th</sup>, 2013

Manufacturer: DuraCore Pty Ltd C/- MWM Advisory Pty Ltd (Level 4 – 3221 Central Place,  
Carrara QLD 4211)

Sample Description: Densi Crete

Date Tested: September 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)  
Content of Paints and Related Coatings

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Densi Crete</b>
Architectural Sealants  250 grams per Litre as VOC content per material	<b>&lt;1 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV130929b**