

VOC Content Test Certificate

Monday, November 18th, 2013

Manufacturer: DuraCore Pty Ltd C/- MWM Advisory Pty Ltd (Level 4 – 3221 Central Place,
Carrara QLD 4211)

Sample Description: Moisture Proof

Date Tested: September 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)
Content of Paints and Related Coatings

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Moisture Proof
Architectural Sealants 250 grams per Litre as VOC content per material	<1 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130929b